



## TREATMENT LIMITATIONS AND TECHNIQUE

MODEL #	GPM	pH	HARDNESS GPG	IRON PPM	MANGANESE PPM	COLOR	ORGANICS
MCAC-25T	6.0	NAT	15.0	1.5	0.5	NAT	NAT
MCA-30T	8.5	NAT	40.0	5.0	2.0	NAT	NAT
MCA-45T	8.5	NAT	60.0	5.0	2.0	NAT	NAT
MCA-60T	10.0	NAT	80.0	5.0	2.0	NAT	NAT
MUN-10	5.0	5.6	NAT	NAT	NAT	NAT	NAT
MUN-13	7.0	5.6	NAT	NAT	NAT	NAT	NAT
CFES-20T	5.0	NAT	40.0	15.0	3.0	YES	NAT
CFES-30T	7.0	NAT	45.0	15.0	3.0	YES	NAT
CFES-40T	10.0	NAT	50.0	15.0	3.0	YES	NAT
CNS-20T	5.0	5.6	10.0	15.0	3.0	YES	NAT
CNS-30T	7.0	5.6	10.0	15.0	3.0	YES	NAT
CNS-40T	10.0	5.6	10.0	15.0	3.0	YES	NAT
CTS-20T	6.0	NAT	40.0	1.0	.5	NAT	YES
CTS-30T	7.0	NAT	45.0	1.0	.5	NAT	YES
CTS-40T	10.0	NAT	50.0	1.0	.5	NAT	YES
MCA-AC-10	6.0	NAT	NAT	NAT	NAT	NAT	YES
MCA-AC-13	8.0	NAT	NAT	NAT	NAT	NAT	YES
MAC-16-1.25	10.0	NAT	NAT	NAT	NAT	NAT	YES
MCA-AN-10	5.0	5.6	NAT	NAT	NAT	YES	NAT
MCA-AN-13	7.0	5.6	NAT	NAT	NAT	YES	NAT
MAN-16-1.25	10.0	5.6	NAT	NAT	NAT	YES	NAT
MCA-FE-10B	5.0	NAT	NAT	8.0	3.0	YES	NAT*
MCA-FE-13B	7.0	NAT	NAT	8.0	3.0	YES	NAT*
MFE-16-1.25B	10.0	NAT	NAT	8.0	3.0	YES	NAT*
MCA-FE-10G	5.0	NAT	NAT	8.0	3.0	YES	NAT*
MCA-FE-13G	7.0	NAT	NAT	8.0	3.0	YES	NAT*
MFE-16-1.25G	10.0	NAT	NAT	8.0	3.0	YES	NAT
MCA-MM-10	5.0	NAT	NAT	NAT	NAT	YES	NAT**
MCA-MM-13	7.0	NAT	NAT	NAT	NAT	YES	NAT**
MM-16-1.25	10.0	NAT	NAT	NAT	NAT	YES	NAT**

**These limitations are general guides only. There are many other important parameters to consider before making a recommendation. Contact a representative of Master Water Conditioning. Master Water Conditioning provides free water analysis and recommendations.**

\*For guaranteed Iron Manganese reduction, a water softener must follow a filter.

\*\*Multi Media filters are for discolored water, not sand or fine grit.

NAT – Not applicable technique. Treatment equipment will malfunction if this condition is present.